

Rand Crafts - IPP Units 1 & 2 for 2 projects draft verbiage

From: "Milka Radulovic" <milkar@utah.gov>
To: "Rand Crafts" <RAND-C@ipsc.com>
Date: 2/4/2004 10:18 AM
Subject: IPP Units 1 & 2 for 2 projects draft verbiage

To reply to the comments made by Grand Canyon Trust and Utah Chapter Sierra Club we would need the following statements:

1. IPSC needs to provide a statement that modification approved in the DAQE-049-02 and CO Major PSD modification in the ITA DAQE-IN0327009-03 at Intermountain Power Plant's Unit 1 and 2 are two separate projects.
- 2 Addition of OFA for Units 1 and 2 is not necessary to meet NO_x increase over the base line emissions below significant levels for triggering PSD review.
- 3 Provide supporting explanation why OFA is a separate project from the first project (DAQE-049-02).
- 4 IPP will continue to monitor emissions increases from the first project base line emissions as required in the DAQE-049-02 Condition 25 "to provide a reasonable means of determining whether a significant increase in representative actual emissions from the proposed change occurs within 5 years following the change[m1]"

[m1]Federal Register 57, page 32314, dated July 21, 1992
Milka Radulovic
Division of Air Quality
801-536-4232
Milkar@utah.gov